

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE <div style="text-align: center;">J</div>		PAGE OF PAGES <div style="text-align: center;">1 2</div>	
2. AMENDMENT/MODIFICATION NO. 0003		3. EFFECTIVE DATE 24-Jun-2004		4. REQUISITION/PURCHASE REQ. NO. W22W9K-4054-4871		5. PROJECT NO.(If applicable)	
6. ISSUED BY U. S. ARMY ENGINEER DISTRICT, LOUISVILLE 600 DR. MARTIN LUTHER KING, JR. PLACE ROOM 821 LOUISVILLE KY 40202-2230		CODE W912QR		7. ADMINISTERED BY (If other than item 6) MILITARY/RESERVE TEAM 600 DR. M. L. KING, JR. PL., RM 821 ATTN: DEBRAUH M. LARDNER LOUISVILLE KY 40202-2230		CODE DACA27	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X		9A. AMENDMENT OF SOLICITATION NO. W912QR-04-R-0013	
				X		9B. DATED (SEE ITEM 11) 26-Feb-2004	
						10A. MOD. OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) Subject Solicitation No. W912QR-04-R-0013 for Trainee Dining Facility, Ft. Knox, KY, is amended for clarification as follows: See attached.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: _____ EMAIL: _____			
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 24-Jun-2004	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

SECTION SF 30 - BLOCK 14 CONTINUATION PAGE

The following have been added by full text:

AMDT. #0003

-Section 01020, Para 29.3.1.8 was changed by Amendment #0002 to eliminate the need to contact Nolin Electric for proposal pricing. Primary electric service installation pricing is not to be included in the proposal. Coordination of final design, however, will be required with Nolin.

-To clarify the issue of the 36 inch storm sewer (Dwg. C202) - When the old barracks were demolished, portions of the existing storm sewer were covered up. Inverts of the existing structures in question are not available from the field survey nor from the Ft. Knox GIS database or records. Designers should assume a 1% slope on the 36-inch pipes up to the tie in point shown on Sheet C202. As required in the RFP, this and all of the survey data provided will have to be verified in the field prior to start of design/construction. A further clarification of the requirement is that the designer shall not assume that the 36-inch pipe is adequate for the drainage required. Calculations shall be performed with the criteria in the RFP and with the assumption made above to verify the pipe size required.

-To clarify the issue of survey control, the horizontal control is based on Ft. Knox horizontal datum (NAD 83) and the vertical control is based on Ft. Knox vertical datum (NGVD 1929). The surveyor who performed the survey for the RFP can be available (with 48 hours notice) to meet with the contractor's surveyor to point out the control locations if they are not obvious on the site or cannot be reproduced from Ft. Knox monumentation.

(End of Summary of Changes)